

STATE OF CONNECTICUT  
 DEPARTMENT OF CONSUMER PROTECTION  
 REAL ESTATE & PROFESSIONAL TRADES DIVISION  
 WELL DRILLING COMPLETION REPORT  
 165 Capitol Avenue, Hartford, Connecticut 06106

DO NOT fill in

STATE WELL NO.

OTHER NO.

OWNER	NAME <b>Scott Lagace</b>			ADDRESS <b>215 Long Hill Road, Andover, CT</b>					
LOCATION OF WELL	(No & Street) <b>3 Hillside Road</b>		(Town) <b>East Haddam</b>	(Lot Number)					
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC <input type="checkbox"/> PUBLIC SUPPLY		<input type="checkbox"/> BUSINESS ESTABLISHMENT <input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> FARM <input type="checkbox"/> AIR CONDITIONING		<input type="checkbox"/> TEST WELL <input type="checkbox"/> OTHER (Specify)			
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY		<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION		<input type="checkbox"/> OTHER (Specify)			
CASING DETAILS	LENGTH (feet) <b>70</b>	DIAMETER (inches) <b>6</b>	WEIGHT PER FOOT <b>17 lbs</b>	<input checked="" type="checkbox"/> THREADED	<input type="checkbox"/> WELDED	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS <b>4</b>	YIELD (GPM) <b>6</b>				
WATER LEVEL	MEASURE FROM LAND SURFACE – STATIC (Specify feet) <b>30 feet</b>			DURING YIELD TEST (feet) <b>315</b>			Depth of Completed Well in feet <b>325</b>		
SCREEN DETAILS	MAKE							LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED		Diameter of well including gravel pack (inches)	GRAVEL SIZE (inches)		FROM (feet)	TO (feet)
DEPTH FROM LAND TO SURFACE FEET TO FEET		FORMATION DESCRIPTION			Sketch exact location of well with distances to at least two permanent landmarks				
0	3	<b>Hardpan</b>							
3	58	<b>Sand &amp; Gravel</b>							
58	62	<b>Soft Bedrock</b>							
62	325	<b>Bedrock</b>							
If yield was tested at different depths during drilling, list below									
FEET	GALLONS PER MINUTE								
DATE WELL COMPLETED <b>3-21-22</b>	PERMIT NO	REGISTRATION NO <b>W1-368</b>			DATE OF REPORT <b>3-23-22</b>	WELL DRILLER (Signature) 			