

Initial Unannounced Full/Partial Follow-up Location Change Investigation Other Initial Follow-up

SUPPLEMENTAL REPORT OF INSPECTION

Name of Program/Provider: Melissa Cardoso Guerrero Date: 5/31/22 Time: 9:13am

Location Address: 183 Batchley Ave New Haven Telephone #: 203 906 7572

e-mail address: cardosolcunningcenter@gmail.com License #: Pending Expiration Date: —

Capacity: 6+3 # of Children Present: 0 # of Staff Present: 1

Consent to Inspect Family Child Care Home	I agree to allow the Office of Early Childhood to have access to and inspect this facility and all child care records as required by Family Child Care Home Regulations. Provider/Applicant/Substitute's Signature <u>Melissa Cardoso</u>
--	--

Purpose of visit: Initial Follow-up

Observations/Corrections needed:

NS #23 Observed cubbies secured to the wall. Observed hole outside in the ground, covered completely with bricks. Rusted metal piece was already removed from area.

NS #24 Observed door with lock behind. ^{EEU} In compliance. No flammables accessible to children. In compliance.

S #24 Report of lead test of sample given to provider lead paint was identified on sample taken on previous visit.

NS #28 Observed electrical cord secured. In compliance.

S #29 Observed locked door from the outside in one of the emergency exits. Unable to open the door from the child care area.

NS #31 Observed stairs outside with protection on sides and gate at entrance. In compliance.

NS #34 Observe working smoke detector installed in the attic.

S = Substantiated NS = Not Substantiated P = Pending (if applicable)

Operators/providers are required by regulations and statutes to be in compliance at all times.

CORRECTIVE PLAN SHALL BE RETURNED TO OEC BY: Prior to licensure.

Signature: Carmen Elisa Valenzuela
(OEC Representative)
Print Name: Carmen Elisa Valenzuela

Signature: Melissa Cardoso Guerrero
(Person in Charge)
Print Name: Melissa Cardoso Guerrero

SUPPLEMENTAL REPORT OF INSPECTION

Name of Program/Provider: Melissa Cardoso License # Pending Date: 5/31/22

Observations/Corrections needed:

- NS # 35 Observed working Carbon Dioxide Detectors installed in each level of the home / program. In compliance.
- NS # 46 Observed water temperature at 80°F In compliance.

S = Substantiated NS = Not Substantiated P = Pending (if applicable)

Operators/providers are required by regulations and statutes to be in compliance at all times.

Signature: Carmen Elva Obayuela
(OEC Representative)

Print Name: Carmen E. Obayuela

CORRECTIVE PLAN SHALL BE RETURNED TO

Signature: Melissa Cecilia Guerrero
(Person in Charge)

OEC BY: Prior to licensure.

Print Name: Melissa Cardoso Guerrero