

2023-602

Initial Unannounced Full/Partial Follow-up Location Change Investigation Other _____

SUPPLEMENTAL REPORT OF INSPECTION

Name of Program/Provider: Kiddie Academy of Rocky Hill Date: 7/19/23 Time: 10 am

Location Address: 158 New Britain Avenue Rocky Hill Telephone #: 860-436-5307

e-mail address: Natalia.Doran@kiddieacademy.net License #: 70339 Expiration Date: 12/31/24

Capacity: 156/56 # of Children Present: 57 # of Staff Present: 15

Consent to Inspect I agree to allow the Office of Early Childhood to have access to and inspect this facility and all
Family Child Care Home child care records as required by Family Child Care Home Regulations.
Provider/Applicant/Substitute's Signature _____

Purpose of visit: Investigation / Complaint 2023-602

Observations/Corrections needed:

PIC Amanda DiVicino - Director - Natalia Doran - Owner
(S) 19a-79-7a(c)(2) Physical Plant - General Requirement - The program's HVAC/heating/AC system was noted to not be in a good state of repair, as certain areas of the building (where children are) become hot. The temperature in the building is not regulating correctly and/or accurately causing the heat to sporadically come on when ac should be on due to inside and outside temperatures.

(S) = Substantiated NS = Not Substantiated P = Pending (if applicable)

Operators/providers are required by regulations and statutes to be in compliance at all times.

Signature: Valecia Williams
(OEC Representative)

Print Name: Valecia Williams

CORRECTIVE PLAN SHALL BE RETURNED TO OEC BY: 7/28/23

Signature: _____
(Person in Charge)

Print Name: Amanda DiVicino