



DIVISION OF LICENSING

450 Columbus Boulevard, Suite 302, Hartford, Connecticut 06103
 Phone (800)282-6063 or (860)500-4450 Fax (860)326-0552
 Email: oe.licensing@ct.gov Website: www.ctoec.org

CHILD CARE CENTER/GROUP CHILD CARE HOME INSPECTION

Program Name	NICKY'S STARTLIGHT DAYCARE				License Number	DCCC		Date of Inspection	08/02/2024	
					Expiration Date			Time of Inspection	09:15 AM	
Address	15 NORTON ST NEW HAVEN CT 06511-4237				Telephone	(475) 254-8945		Licensed Capacity	16	
					Hours of Operation	6:30am-11:30pm Monday-Friday		Infant/Toddler Capacity	13	
Is this a Change of Address?	Yes?		No?	X				Summer Care	Open	
New Address					Minimum Age Served	6 weeks	Maximum Age Served	12 years	Water Supply	Public Water
					Program's Email	starlight2daycare@yahoo.com				
Operator	NICKY'S STARLIGHT 2 DAYCARE, LLC				Name of Inspector	Bridget Merrill				
Director	ANTWAN SUTTON				Inspector's Email	bridget.merrill@ct.gov				
Key:	Compliant = X	# of Infants - Toddlers Present	0	# of Total Children Present	0	# of Staff Present	2	Type of Inspection	INITIAL CREDENTIAL INSPECTION	
Non-Compliant = O										

LICENSURE PROCEDURES 19a-79-2a

X	1. Local Health Inspection	
	Date: 06/20/2022	
X	1a. False or Misleading Statements	

ADMINISTRATION 19a-79-3a

X	1b. Administration	
X	1bb. Capacity	
X	2. New Staff – Employee Orientation	
X	3. Annual Staff Policy Training	
X	3b. Managing child behavior	
X	4. Documentation of Behavior M. Tech Discussed w/parents	
X	4b. Failure to report	

X	5. Notification of Change	
X	6. Program policies	Including discipline, supervision, child protection, general operating, personnel, closing time
X	7. Daily Attendance Records- staff and children	

ITEMS POSTED – ACCESSIBLE

X	8. License	
X	9. Fire Marshal certificate	
	Date	05/08/2024
X	10. OEC Complaint procedure	
	11. Food Service Certificate	N/A?
	Date	X
X	12. Menus	
X	13. Emergency plans	
X	14. No Smoking Signs	
X	15. Radon Test	N/A?
	Date	Results
	04/22/2020	.4
X	15a. Developmental Milestones	
X	15b. Access	
X	15bb. 32-36 mths enrolled in prek-permissions	

STAFFING 19a-79-4a

X	15c. Staffing	
X	16. Staff Health records – TB tests	
X	17. Professional development	
X	18. Disciplinary actions	
X	18b. Background checks	

X	19. Designated Head Teacher					
X	20. Two Staff present					
X	20a. Staff Qualities					
X	21. Ratio: 1 staff to 10 children					
X	21b. Supervision					
X	22. Group Size – maximum 20 children					
X	23. Designated director - Training					
X	24. CPR Certified Staff (Group Home N/A)					
X	25. First Aid Trained Staff					
X	26. Consultants- Agreements and Contracts					
X	27. Logs – Visits documented					
	Not in Compliance?	Education	Health	Social Service	Dental	Dietician N/A? X
	Contracts					
	Logs					
	Do they take children swimming?	N SWIMMING				
X	28. Non-swimmers identified					
X	29. Staff/Child Ratios					
X	30. CPR certified staff (20 years of age)					
X	31. Lifeguard certified - supervision					
RECORD KEEPING 19a-79-5a						
X	32. Enrollment information					
X	33. Emergency medical permission					
X	34. Authorized release permission					
X	35. Field trip permission					
X	36. Transportation permission					

<input checked="" type="checkbox"/>	37. Child health records and immunizations		
<input checked="" type="checkbox"/>	38. Individual care plan (signed by parents and staff)		
<input checked="" type="checkbox"/>	39. Injury, Illness, Accident reports		
HEALTH AND SAFETY 19a-79-6a			
<input checked="" type="checkbox"/>	40. Nutritious snacks and meals (required food groups)		
<input checked="" type="checkbox"/>	41. Proper refrigeration (max 45°)		
<input checked="" type="checkbox"/>	42. Kitchen separated	N/A?	
<input checked="" type="checkbox"/>	43. Hand washing – before eating or food handling		
<input type="checkbox"/>	44. First Aid Kit(s) – Indoor, Outdoor, Field Trips, Inventory	Failed to maintain complete first aid kit(s) for indoor/ outdoor use. Indoor kit was missing 1 cold pack, 1 triangular bandage, roll gauze & manual less than 5yrs in print. Outdoor kit was missing 1 cold pack, 1 triangular bandage, CPR mouth shield & maual less than 5 yrs in print.	
PHYSICAL PLANT 19a-79-7a			
<input checked="" type="checkbox"/>	45. License premises – clean, good repair, hazard free		
<input checked="" type="checkbox"/>	47b. Plans for new construction, expansion, renovation or conversion		
<input checked="" type="checkbox"/>	48. Sanitary drinking fountains – disposable cups		
<input checked="" type="checkbox"/>	49. Lead Water Test (N/A?) 02/09/2024	Bacterial/Chemical Test (N/A?)	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	50. Walkways maintained		
<input checked="" type="checkbox"/>	51. Designated staff toilet/sink		
<input checked="" type="checkbox"/>	52. All openings for ventilation screened		
<input checked="" type="checkbox"/>	53. Windows protected to prevent falls		
<input checked="" type="checkbox"/>	54. Glass protected up to 36"		
<input checked="" type="checkbox"/>	55. Overhead doors – locking devices, spring protectors		
<input checked="" type="checkbox"/>	56. Exits, Hallways and Stairs unobstructed		

X	57. Individual storage of clothing and bedding	
X	58. Smoking prohibited	
X	59. Matches and lighters inaccessible	
X	60. Electrical safety – outlets/cords	
X	61. Toileting needs met	
X	62. Required toilets, sinks, supplies	
X	63. Potty chairs – nonporous, emptied, disinfected	
X	64. Hand washing after toileting – staff and children	
X	65. Ventilation in toilet rooms	
X	66. Air temperature 65 degrees, thermometer affixed	
X	67. Water temperature 60° – 115°	
X	68. Portable space heaters	
X	69. Walls, ceilings, floors and rugs – clean, good repair	
X	70. Rugs secure	
X	71. Hot water, steam pipes protected	
X	72. Working phone on each level	
X	73. Emergency numbers posted	
○	74. Adequate lighting - 50/30 candle feet	Failed to maintain at least 50 candle feet of light in rooms used for reading, painting and other close work. Observed lighting in all rooms between 27-30 candle feet.
X	75. Light fixtures shielded, shatter proof	
X	76. Potentially hazardous substances locked	
X	77. Garbage, rubbish disposed daily	

X	78. Stairs protected, good repair, handrails	
X	79. Pets – maintained, care plan	Y/N N
X	80. Operable CO detector on each level	N/A? Y
X	81. Program space-adequate square footage per child	
X	82. Equipment clean, good repair, safe, non-toxic	
X	83. Cots stored, maintained, adequate number	
X	84. Developmentally appropriate equipment	
X	85. Hot tubs, spas, saunas – locked and inaccessible	Y/N N
X	86. No weapons, no facsimile of a firearm on premises	
OUTDOOR SPACE		
X	87. Outdoor space - adequate square footage per child	
○	88. Impact absorbing material under equipment	Failed to ensure a minimum of 8 inches of impact absorbing materials under slide.
○	89. Playground free from hazards	Failed to ensure the playground is free of glass, debris, holes and other hazards. Observed toy kitchen sets in disrepair.
X	92. Equipment anchored, safely arranged	
X	93. Outdoor play area protected, fenced	
X	94. Drinking water available, accessible	
EDUCATIONAL REQUIREMENTS 19a-79-8a		
X	95. Written plan for daily program available to parents/staff	
X	96. Schedule – Activity choices and Program	Activity choices: developmentally appropriate, flexible, meets individual needs Program includes: indoor/outdoor, gross/fine motor skills, snacks/meals, rest/sleep/quiet time, toileting and clean up
ADMINISTRATION OF MEDICATIONS 19a-79-9a		
X	97. Written policies, procedures	
X	98. Training outline on file	

NONPRESCRIPTION TOPICAL MEDICATIONS						
X	99. Administration, parent permission, MAR					
X	100. Labeling, storage					
ORAL/TOPICAL/INHALENT MEDICATIONS						
X	101. Med trained staff, certificates					
	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%; padding: 2px;">O/T/I</td> <td style="padding: 2px;">Injectable</td> </tr> <tr> <td style="text-align: center; padding: 2px;">Y</td> <td style="text-align: center; padding: 2px;">Y</td> </tr> </table>	O/T/I	Injectable	Y	Y	
O/T/I	Injectable					
Y	Y					
X	102. Authorized prescriber, parent permission, MAR					
X	103. Labeling, storage					
X	104. Unused, expired meds returned/disposed					
SELF-ADMINISTRATION						
X	105. Authorized prescriber, parent permission, MAR					
X	106. Labeling, storage					
X	107. Approved petition for special medication authorization					
No	Is there an approved endorsement?	INFANT/TODDLER ENDORSEMENT 19a-79-10				
X	109. Approved endorsement					
X	110. Ratio: 1 staff to 4 children					
X	111. Group size: no larger than 8					
X	112. Physical barriers, groups of 8 (indoors and outdoors)					
X	113. Adequate sinks in program space					
X	114. Free standing, well-constructed, safe cribs					
X	115. Washable cots					
X	116. Chairs for feeding, stable, safety straps, locking tray					
X	117. Developmentally appropriate tables, chairs, equipment					
X	118. Refrigerators and food prop facilities					

X	119. Diaper area- sturdy, safety rail, nonporous, exclusive use			
X	120. Diaper area- washed, disinfected			
X	121. Diaper area- disposable paper sheets			
X	122. Covered waste receptacle			
X	123. Diaper changing policy posted, followed			
X	124. Hand washing policy posted, followed			
X	125. Individual storage of personal items			
X	126. Cribs/cots washed and disinfected			
X	127. Under 12 months- placed on back for sleeping			
X	128. Alternate sleep position- equipment, medical documentation	Yes X	No	
X	129. Crib, bed used for infant sleeping			
X	130. Crib, bed free from observable hazards			
X	131. Infant toys separate, washed, disinfected daily			
X	132. No toys, objects less than 1/1/4" diameter			
X	133. Plastic bags, balloons, Styrofoam objects inaccessible			
X	134. Health consultant, doc. of visits			
X	135. Infants held for bottles, indiv. attention, tummy time			
X	136. Written statement, feeding schedule from parent			
X	137. Unused portions of liquids discarded			
X	138. Clean Bottles, disp. bottles, approved bottle washing			
X	139. Food served from dish or whole jar served			
X	140. Bottles individually identified with child's name			

OUTDOOR PLAY SPACE - UNDER THREE

X	141. Play space fenced	
X	142. Outdoor equipment developmentally appropriate	
No	Is there an approved endorsement?	SCHOOL AGE ENDORSEMENT 19a-79-11
X	143. Approved endorsement	
X	144. Activity choices appropriate	
X	145. Ratio – 1 staff to 10 children	
X	146. Group size – maximum 20 children	
X	147. Education Consultant appropriate	
No	Is there an approved endorsement?	NIGHT CARE ENDORSEMENT 19a-79-12 (10pm-5am)
X	148. Approved endorsement	
X	149. Written program plan, supervision	
X	150. Staff awake and available	
X	151. Cot, crib, bedding, toiletries, sleep apparel	
X	152. Individual storage of personal items	
X	153. Bedding, sleeping apparel laundered weekly	
N	Child with diabetes enrolled?	MONITORING OF DIABETES 19a-79-13
X	154. Written policies and procedures	
X	155. On site staff trained in first aid, glucose testing	
X	156. Training current and documented	
X	157. Supervision of self-administration	
X	158. Equipment, supplies labeled and inaccessible	

X	159. Signed agreement with parents regarding equipment	
X	160. Materials discarded appropriately	
X	161. Authorized prescriber, parent permission	
X	162. Documentation of test results, actions taken	
X	163. Daily written parent notification	

ADDITIONAL VIOLATIONS

	62. Consent Order - Negotiated Corrective Action Plan	N/A?	
		X	

YES or NO?
Yes



WERE VIOLATIONS CITED DURING THIS VISIT?

DISCUSSIONS/COMMENTS

Infant room: $25.3 \times 13.1 - 3.8 \times 18.7 = 260.37 / -35 = 7.4$ ok for 7 children under age 3
 Toddler room: $18.5 \times 13.6 - 1.4 \times 4 - 2 \times 1.4 = 243.2 / -35 = 6.9$ ok for 6 children under age 3
 Preschool/ school age room: $14.8 \times 7.6 - .8 \times 8.6 = 105.6 / -35 = 3.0$ ok for 3 children over age 3
 Outdoor play area: $27.4 \times 34.3 - 4.9 \times 7.8 = 901.6 / -75 = 12.0$ ok for 8 children under age 3 or 12 children over age 3
 Indoor capacity= 16 total with 13 under age 3

NOTE: Items left blank on this form were not monitored during this visit.
 Only the regulations marked as compliant, non-compliant or not applicable were monitored or discussed.

APPLICANTS: You MAY NOT OPERATE until all requirements have been met and a license has been issued by the Agency.

 (Signature of OEC Representative)	 (Signature of Person in Charge)	DATE CORRECTIONS DUE BY:
Bridget Merrill (Printed Name)	Nicole oeschger (Printed Name)	