CPR-9 Rev. 7/95

STATE OF CONNECTICUT
DEPARTMENT OF CONSUMER PROTECTION
REAL ESTATE & PROFESSIONAL TRADES DIVISION
WELL DRILLING COMPLETION REPORT
450 Columbus Blvd., Suite 801, Hartford, CT 06103

Do NOT fill in
STATE WELL NO.
OTHER NO.

LOCATION OF WELL	(No. & Street) 120 Fletcher Rd (Town) Enfield (Lot Number)
OWNER	NAME Jessica Antonacci; ADDRESS 555 Taylor Rd Enfield CT 06082
PROPOSED USE OF WELL	☐ DOMESTIC ☐ BUSINESS ESTABLISHMENT ☐ FARM ☐ TEST WELL ☐ PUBLIC SUPPLY ☐ INDUSTRIAL ☐ AIR CONDITIONING ☒ OTHER (Specify) well abandonment
DRILLING EQUIPMENT	☐ ROTARY ☐ COMPRESSED AIR PERCUSSION ☐ CABLE PERCUSSION ☐ OTHER (Specify)

CASING DETAILS	LENGTH (feet)	DIAMETER (inches)	WEIGHT PER FOOT	☐ THREADED ☐ WELDED	DRIVE SHOE ☐ YES ☐ NO	WAS CASING GROUTED? ☐ YES ☐ NO
		6"				

YIELD TEST	☐ BAILED ☐ PUMPED ☐ COMPRESSED AIR	HOURS	YIELD (GPM)

WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet)	DURING YIELD TEST (feet)	Depth of Completed Well in feet Abandon
	70'	260'	260'

SCREEN DETAILS	MAKE					LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches)	GRAVEL SIZE (inches)	FROM (feet)	TO (feet)

DEPTH FROM LAND TO SURFACE FEET TO FEET		FORMATION DESCRIPTION Abandon
0	6'	fill
6'	16'	neat cement
16'	260'	bentonite grout

Sketch exact location of well with distances, to at least two permanent landmarks

House was demolished. No dimensions available from house to abandoned well.

GPS location of well
-72.4977 W
41.96781 N

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED	PERMIT NO.	REGISTRATION NO.	DATE OF REPORT	WELL DRILLER (Signature)
7/2/24		30	8/2/24	