



DIVISION OF LICENSING

450 Columbus Boulevard, Suite 302, Hartford, Connecticut 06103
 Phone (800)282-6063 or (860)500-4450 Fax (860)326-0552
 Email: oe.licensing@ct.gov Website: www.ctoec.org

CHILD CARE CENTER/GROUP CHILD CARE HOME INSPECTION

Program Name	NEW HAVEN YMCA YOUTH CENTER				License Number	DCCC.14328	Date of Inspection	08/22/2024		
					Expiration Date	6/30/2026	Time of Inspection	08:50 AM		
Address	52 HOWE ST NEW HAVEN CT 06511-4610				Telephone	(203) 776-9622	Licensed Capacity	120		
					Hours of Operation	FROM: 7:30AM TO: 6:00PM	Infant/Toddler Capacity	16		
Is this a Change of Address?	Yes?		No?	X			Summer Care	Open		
New Address					Minimum Age Served	12 months	Maximum Age Served	12 years	Water Supply	Public Water
					Program's Email	ekelly@cccymca.org				
Operator	CENTRAL CONNECTICUT COAST YMCA				Name of Inspector	Bridget Merrill				
Director	AISHAH EBONY BRICE				Inspector's Email	bridget.merrill@ct.gov				
Key: Compliant = X Non-Compliant = O	# of Infants - Toddlers Present	7	# of Total Children Present	21	# of Staff Present	7	Type of Inspection	UNANNOUNCED INSPECTION - FULL		

LICENSURE PROCEDURES 19a-79-2a

O	1. Local Health Inspection Date: 03/23/2022	Failed to maintain current local health inspection within the past 2yrs.
X	1a. False or Misleading Statements	

ADMINISTRATION 19a-79-3a

X	1b. Administration	
X	1bb. Capacity	
X	2. New Staff – Employee Orientation	
X	3. Annual Staff Policy Training	
X	3b. Managing child behavior	
X	4. Documentation of Behavior M. Tech Discussed w/parents	
X	4b. Failure to report	

X	5. Notification of Change	
X	6. Program policies	Including discipline, supervision, child protection, general operating, personnel, closing time
X	7. Daily Attendance Records- staff and children	
ITEMS POSTED – ACCESSIBLE		
X	8. License	
O	9. Fire Marshal certificate	Failed to maintain a current fire marshal inspection within 1yr.
	Date	04/01/2023
X	10. OEC Complaint procedure	
O	11. Food Service Certificate	<u>N/A?</u>
	Date	05/01/2024
		Failed to post current Food Service Certificate. Posted certificate is expired.
X	12. Menus	
X	13. Emergency plans	
X	14. No Smoking Signs	
X	15. Radon Test	<u>N/A?</u>
	Date	Results
	04/12/1999	.4
X	15a. Developmental Milestones	
X	15b. Access	
O	15bb. 32-36 mths enrolled in prek-permissions	Failed to obtain written permission from parents and/or the director for prek enrollment for 1 child.
STAFFING 19a-79-4a		
X	15c. Staffing	
O	16. Staff Health records – TB tests	Failed to maintain medical statement(s) & TB test(s) for 1 staff. Failed to maintain current medical statement(s) for 1 staff whose physical is more than 2yrs old.
X	17. Professional development	
X	18. Disciplinary actions	
X	18b. Background checks	

X	19. Designated Head Teacher					
X	20. Two Staff present					
X	20a. Staff Qualities					
X	21. Ratio: 1 staff to 10 children					
X	21b. Supervision					
X	22. Group Size – maximum 20 children					
X	23. Designated director - Training					
X	24. CPR Certified Staff (Group Home N/A)					
X	25. First Aid Trained Staff					
X	26. Consultants- Agreements and Contracts					
X	27. Logs – Visits documented					
	Not in Compliance?	Education	Health	Social Service	Dental	Dietician N/A?
	Contracts					
	Logs					
	Do they take children swimming? Y SWIMMING					
X	28. Non-swimmers identified					
X	29. Staff/Child Ratios					
X	30. CPR certified staff (20 years of age)					
X	31. Lifeguard certified - supervision					
RECORD KEEPING 19a-79-5a						
X	32. Enrollment information					
X	33. Emergency medical permission					
X	34. Authorized release permission					
X	35. Field trip permission					
X	36. Transportation permission					

<input type="radio"/>	37. Child health records and immunizations	Failed to maintain current health records for 1 child.	
<input type="radio"/>	38. Individual care plan (signed by parents and staff)	Failed to maintain complete individual care plans which includes staff signatures for 1 child.	
<input checked="" type="checkbox"/>	39. Injury, Illness, Accident reports		
HEALTH AND SAFETY 19a-79-6a			
<input checked="" type="checkbox"/>	40. Nutritious snacks and meals (required food groups)		
<input checked="" type="checkbox"/>	41. Proper refrigeration (max 45°)		
<input checked="" type="checkbox"/>	42. Kitchen separated	N/A?	
<input checked="" type="checkbox"/>	43. Hand washing – before eating or food handling		
<input checked="" type="checkbox"/>	44. First Aid Kit(s) – Indoor, Outdoor, Field Trips, Inventory		
PHYSICAL PLANT 19a-79-7a			
<input type="radio"/>	45. License premises – clean, good repair, hazard free	Failed to maintain the building, equipment and services. Observed dusty wall vents in C,D. Dusty bathroom vents in preschool & toddler bathrooms, soiled microwave in kitchen & lights/ bulbs out in toddlers, stained ceiling tiles in homework & school age rooms, CONTINUED IN DISCUSSION SECTION...	
<input checked="" type="checkbox"/>	47b. Plans for new construction, expansion, renovation or conversion		
<input checked="" type="checkbox"/>	48. Sanitary drinking fountains – disposable cups		
<input checked="" type="checkbox"/>	49. Lead Water Test (N/A?) 02/24/2023	Bacterial/Chemical Test (N/A?)	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	50. Walkways maintained		
<input checked="" type="checkbox"/>	51. Designated staff toilet/sink		
<input checked="" type="checkbox"/>	52. All openings for ventilation screened		
<input checked="" type="checkbox"/>	53. Windows protected to prevent falls		
<input checked="" type="checkbox"/>	54. Glass protected up to 36"		
<input checked="" type="checkbox"/>	55. Overhead doors – locking devices, spring protectors		
<input checked="" type="checkbox"/>	56. Exits, Hallways and Stairs unobstructed		

X	57. Individual storage of clothing and bedding	
X	58. Smoking prohibited	
X	59. Matches and lighters inaccessible	
X	60. Electrical safety – outlets/cords	
X	61. Toileting needs met	
X	62. Required toilets, sinks, supplies	
X	63. Potty chairs – nonporous, emptied, disinfected	
X	64. Hand washing after toileting – staff and children	
X	65. Ventilation in toilet rooms	
X	66. Air temperature 65 degrees, thermometer affixed	
X	67. Water temperature 60° – 115°	
X	68. Portable space heaters	
X	69. Walls, ceilings, floors and rugs – clean, good repair	
X	70. Rugs secure	
X	71. Hot water, steam pipes protected	
X	72. Working phone on each level	
X	73. Emergency numbers posted	
X	74. Adequate lighting - 50/30 candle feet	
X	75. Light fixtures shielded, shatter proof	
X	76. Potentially hazardous substances locked	
X	77. Garbage, rubbish disposed daily	

X	78. Stairs protected, good repair, handrails		
X	79. Pets – maintained, care plan	Y/N N	
○	80. Operable CO detector on each level	N/A? Y	Failed to maintain at least 1 operable carbon monoxide detector on each occupied level. Observed no operable CO detector on the second floor in the gym area.
X	81. Program space-adequate square footage per child		
○	82. Equipment clean, good repair, safe, non-toxic		Failed to ensure that equipment is free from rust in preschool, toddler & staff bathroom metal rings behind toilets & on stall walls in men's/ boys pool bathroom.
X	83. Cots stored, maintained, adequate number		
X	84. Developmentally appropriate equipment		
X	85. Hot tubs, spas, saunas – locked and inaccessible	Y/N N	
X	86. No weapons, no facsimile of a firearm on premises		
OUTDOOR SPACE			
X	87. Outdoor space - adequate square footage per child		
X	88. Impact absorbing material under equipment		
X	89. Playground free from hazards		
X	92. Equipment anchored, safely arranged		
X	93. Outdoor play area protected, fenced		
X	94. Drinking water available, accessible		
EDUCATIONAL REQUIREMENTS 19a-79-8a			
X	95. Written plan for daily program available to parents/staff		
X	96. Schedule – Activity choices and Program	Activity choices: developmentally appropriate, flexible, meets individual needs Program includes: indoor/outdoor, gross/fine motor skills, snacks/meals, rest/sleep/quiet time, toileting and clean up	
ADMINISTRATION OF MEDICATIONS 19a-79-9a			
X	97. Written policies, procedures		
X	98. Training outline on file		

NONPRESCRIPTION TOPICAL MEDICATIONS						
X	99. Administration, parent permission, MAR					
X	100. Labeling, storage					
ORAL/TOPICAL/INHALENT MEDICATIONS						
X	101. Med trained staff, certificates					
	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%; text-align: center;">O/T/I</td> <td style="width: 90%; text-align: center;">Injectable</td> </tr> <tr> <td style="text-align: center;">Y</td> <td style="text-align: center;">Y</td> </tr> </table>	O/T/I	Injectable	Y	Y	
O/T/I	Injectable					
Y	Y					
O	102. Authorized prescriber, parent permission, MAR	Failed to maintain current written orders for Albuterol in Rm B for 1 child whose authorization expired 8-18-24.				
X	103. Labeling, storage					
X	104. Unused, expired meds returned/disposed					
SELF-ADMINISTRATION						
X	105. Authorized prescriber, parent permission, MAR					
X	106. Labeling, storage					
X	107. Approved petition for special medication authorization					
Yes	Is there an approved endorsement?	INFANT/TODDLER ENDORSEMENT 19a-79-10				
X	109. Approved endorsement					
X	110. Ratio: 1 staff to 4 children					
X	111. Group size: no larger than 8					
X	112. Physical barriers, groups of 8 (indoors and outdoors)					
X	113. Adequate sinks in program space					
X	114. Free standing, well-constructed, safe cribs					
X	115. Washable cots					
X	116. Chairs for feeding, stable, safety straps, locking tray					
X	117. Developmentally appropriate tables, chairs, equipment					
X	118. Refrigerators and food prep facilities					

X	119. Diaper area- sturdy, safety rail, nonporous, exclusive use			
X	120. Diaper area- washed, disinfected			
X	121. Diaper area- disposable paper sheets			
X	122. Covered waste receptacle			
X	123. Diaper changing policy posted, followed			
X	124. Hand washing policy posted, followed			
X	125. Individual storage of personal items			
X	126. Cribs/cots washed and disinfected			
X	127. Under 12 months- placed on back for sleeping			
X	128. Alternate sleep position- equipment, medical documentation	Yes	No	
			X	
X	129. Crib, bed used for infant sleeping			
X	130. Crib, bed free from observable hazards			
X	131. Infant toys separate, washed, disinfected daily			
X	132. No toys, objects less than 1/1/4" diameter			
X	133. Plastic bags, balloons, Styrofoam objects inaccessible			
X	134. Health consultant, doc. of visits			
X	135. Infants held for bottles, indiv. attention, tummy time			
X	136. Written statement, feeding schedule from parent			
X	137. Unused portions of liquids discarded			
X	138. Clean Bottles, disp. bottles, approved bottle washing			
X	139. Food served from dish or whole jar served			
X	140. Bottles individually identified with child's name			

OUTDOOR PLAY SPACE - UNDER THREE

X	141. Play space fenced	
X	142. Outdoor equipment developmentally appropriate	
Yes	Is there an approved endorsement?	SCHOOL AGE ENDORSEMENT 19a-79-11
X	143. Approved endorsement	
X	144. Activity choices appropriate	
X	145. Ratio – 1 staff to 10 children	
X	146. Group size – maximum 20 children	
X	147. Education Consultant appropriate	
No	Is there an approved endorsement?	NIGHT CARE ENDORSEMENT 19a-79-12 (10pm-5am)
	148. Approved endorsement	
	149. Written program plan, supervision	
	150. Staff awake and available	
	151. Cot, crib, bedding, toiletries, sleep apparel	
	152. Individual storage of personal items	
	153. Bedding, sleeping apparel laundered weekly	
N	Child with diabetes enrolled?	MONITORING OF DIABETES 19a-79-13
X	154. Written policies and procedures	
X	155. On site staff trained in first aid, glucose testing	
X	156. Training current and documented	
X	157. Supervision of self-administration	
X	158. Equipment, supplies labeled and inaccessible	

X	159. Signed agreement with parents regarding equipment	
X	160. Materials discarded appropriately	
X	161. Authorized prescriber, parent permission	
X	162. Documentation of test results, actions taken	
X	163. Daily written parent notification	

ADDITIONAL VIOLATIONS

62. Consent Order - Negotiated Corrective Action Plan	N/A?	
---	------	--

YES or NO?
Yes



WERE VIOLATIONS CITED DURING THIS VISIT?

DISCUSSIONS/COMMENTS

#45- Observed peeling paint in women's/ girls pool bathroom on wall under red square & in first stall & in Rm B in block/ transportation area.
Discussed/ gave program copy of new OEC complaint procedure.

NOTE: Items left blank on this form were not monitored during this visit.
Only the regulations marked as compliant, non-compliant or not applicable were monitored or discussed.

APPLICANTS: You MAY NOT OPERATE until all requirements have been met and a license has been issued by the Agency.

 (Signature of OEC Representative)	 (Signature of OEC Representative)	DATE CORRECTIONS DUE BY:	 (Signature of Person in Charge)
Bridget Merrill (Printed Name)	 (Printed Name)	09/05/2024	Kara Uzzle (Printed Name)