

Initial Unannounced Full/Partial Follow-up Location Change Investigation Other

SUPPLEMENTAL REPORT OF INSPECTION

Name of Program/Provider: Bright Path - Wallingford Date: 8-22-25 Time: 10:02

Location Address: 15 N Plains Industrial Rd Wallingford Telephone #: 203-265-0055

e-mail address: brightpathkids.com License #: 2-26-25 Expiration Date: 9-30-28

Capacity: 194/92 # of Children Present: 72/34 # of Staff Present: 15

Consent to Inspect Family Child Care Home	<i>I agree to allow the Office of Early Childhood to have access to and inspect this facility and all child care records as required by Family Child Care Home Regulations. Provider/Applicant/Substitute's Signature</i>
--	---

Purpose of visit: Partial inspection with local health regarding environmental

Observations/Corrections needed:

19a-79-7a Physical plant

- ⑤ #88 ce)(5) walls, ceilings, floors, rugs:
 - observed dusty ceiling vent in kitchen
 - observed stained ceiling tiles in art closet and toddler 4
 - observed water/staining on ceiling light^{shield} in toddler 3
 - observed areas of exposed wall board in toddler 3 near entrance door and under viewing window
 - observed area wall/joint compound near entrance door/under viewing window. Wall area porous

Director notified OEC and local health of mold found in toddler 3 + 4 and art closet
collected documentation from environmental cleaning/abatement company.

S = Substantiated NS = Not Substantiated P = Pending (if applicable)

Operators/providers are required by regulations and statutes to be in compliance at all times.

CORRECTIVE PLAN SHALL BE RETURNED TO OEC BY: 9/5/25

Signature: Jennifer Schue
(OEC Representative)
Print Name: Jennifer Schue
Signature: Deanna Marra
(Person in Charge)
Print Name: Deanna Marra