

Do NOT fill in
STATE WELL NO.
OTHER NO.

LOCATION OF WELL	(No. & Street) 63 Inwood Road (Town) Darien (Lot Number)													
OWNER	NAME ER Salvatore Associates	ADDRESS 52 Larkin St. Stamford CT												
PROPOSED USE OF WELL	☒ DOMESTIC ☐ BUSINESS ESTABLISHMENT ☐ FARM ☐ TEST WELL ☐ PUBLIC SUPPLY ☐ INDUSTRIAL ☐ AIR CONDITIONING ☐ OTHER (Specify)													
	☐ ROTARY ☒ COMPRESSED AIR PERCUSSION ☐ CABLE PERCUSSION ☐ OTHER (Specify)													
DRILLING EQUIPMENT														
CASING DETAILS	LENGTH (feet) 40	DIAMETER (inches) 6												
	WEIGHT PER FOOT 17	☒ THREADED ☐ WELDED DRIVE SHOE ☒ YES ☐ NO WAS CASING GROUTED? ☒ YES ☐ NO												
YIELD TEST	☐ BAILED ☐ PUMPED ☒ COMPRESSED AIR HOURS 8 YIELD (GPM) 20													
	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 25	DURING YIELD TEST (feet) 290 Depth of Completed Well in feet 300												
SCREEN DETAILS	MAKE													
	SLOT SIZE DIAMETER (inches) IF GRAVEL PACKED: Diameter of well including gravel pack (inches) GRAVEL SIZE (inches) FROM (feet) TO (feet)	LENGTH OPEN TO AQUIFER (feet)												
DEPTH FROM LAND TO SURFACE FEET TO FEET 0 25 Overburden 25 300 Soft grey rock		Sketch exact location of well with distances, to at least two permanent landmarks 												
If yield was tested at different depths during drilling, list below <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 20%;">FEET</th> <th style="width: 80%;">GALLONS PER MINUTE</th> </tr> </thead> <tbody> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> </tbody> </table>			FEET	GALLONS PER MINUTE										
FEET	GALLONS PER MINUTE													
DATE WELL COMPLETED 12/3/25	PERMIT NO. —	REGISTRATION NO. 369 DATE OF REPORT 12/15/25 WELL DRILLER (Signature) CAH												